



WASHINGTON COUNTY VOLUNTEER FIRE & RESCUE
ASSOCIATION STANDARDS MANUAL

Title: Tanker Standard

Effective Date: 02/20/1997

Revision Date(s): 01/01/1999

Approval:

Review without revision:

Number of Pages: 1

SOG Number: 2-15

APPARATUS MINIMUM STANDARD:

- _____ Washington County Fire & Rescue Communication Manual
- _____ Washington County Fire & Rescue mobile radio
- _____ Washington County Fire & Rescue portable radio
- _____ Safety bars/belts for all riding positions
- _____ Hearing protection for all riding positions
- _____ Warning signals, audible and visible in working condition
- _____ Audible back up alarm
- _____ 30 minute flares – eight (8)
- _____ DOT warning reflective triangles – three (3)
- _____ Evacuation horn in cab area – one (1)

EQUIPMENT MINIMUM STANDARD:

- _____ 750 GPM Pump
- _____ 1500 Gallon Booster Tank
- _____ Wheel chocks – two (2)
- _____ 30 min. SCBA with spare bottle for each riding position
- _____ Pick head axes – one (1)
- _____ 15lb multipurpose (ABC) dry chemical extinguisher – one (1)
- _____ Portable handlights – two (2)
- _____ Hydrant wrench – one (1)
- _____ Spanner wrenches – two (2)
- _____ Rubber mallet – one (1)
- _____ Shovel – one (1)
- _____ First aid kit-one (1)
- _____ 20 ft. Hard suction hose & strainer or 20 ft. soft sleeve with hydrant-
Pump intake
- _____ 150 ft. ½ inch or larger pre-connected hose line with nozzle
- _____ 200 ft 2½ inch or larger hand lines with nozzles
- _____ 500 GPM gated discharge rate

Apparatus shall conform to NFPA 1901 when it concerns safety. All riding personnel shall be supplies with conforming protective clothing

Inspected by: _____ Date: _____